



Drawings made available by bfs as to the layout or water pipes for battery filling systems are only examples, which require adaptation for each specific battery grouping. The person responsible for the installation of a battery filling system including the water pipes is also responsible to ensure that all instructions given by the producer of the batteries as well as all relevant instructions by the European Union are followed carefully.  
 (See for instance EU Instruction EN 50272 Para 10.2)


1	12	bfs-plug III (push in)	A51000
1a	12	float	07.....
2	1	T-piece 6/10/6 mm	08T616
3	3m	hose 6mm	08SCH6
4	2m	hose 10mm	08SCH1
5	2	end piece	08END6
6	1	dust cap	09STAC
7	24	hose clamp 6mm	08KLE6
8	4	hose clamp 10mm	08KLE1
9	1	filter cartridge	09FIL1
10	1	connection male	09KUV1
Pos.	Quant.	Description	Part No.

Maßstab/SCALE		Verstärker/MATERIAL	
1999	Datum	Name	
Bearb. 14.12.		Scher	
Gepr.			
Norm			
		H. Klaus GmbH H. Klaus Weg 9 11155 Berlin 030 250 09330 030 250 09331	
Zeichnungs-Nr. / DWG. Nr. A 24 VOLT BATTERY		Maßstab/SCALE Verstärker/MATERIAL SAMPLE FOR THE PIPING OF A 24 VOLT BATTERY	
Nicht tolerierte, Freigelegte nach DIN 15901 UNLESS OTHERWISE SPECIFIED TOLERANCING PER DIN 15901			
Zust.	Änderung	Datum	Name





1	40	bfs-plug III (push in)	A51000
1a	40	float	07.....
2	6	T-piece 10/6/10 mm	08T161
3	1	T-piece 10/10/10 mm	08T111
4	2	angle 10/6	08W116
5	8m	hose 6mm	08SCH6
6	2m	hose 10mm	08SCH1
7	8	end piece	08END6
8	1	dust cap	09STAC
9	80	hose clamp 6mm	08KLE6
10	10	hose clamp 10mm	08KLE1
11	1	filter cartridge	09FIL1
12	1	connection male	09KUV1
Pos.	Quant.	Description	Part No.



Drawings made available by bfs as to the layout or water pipes for battery filling systems are only examples, which require adaptation for each specific battery grouping. The person responsible for the installation of a battery filling system including the water pipes is also responsible to ensure that all instructions given by the producer of the batteries as well as all relevant instructions by the European Union are followed carefully.  
(see for instance EU instruction EN 50272 Para 10.2)

Maßstab/SCALE			
1999	Datum	Name	Werkstoff/MATERIAL
Bearb.	25.10.	Scher	SAMPLE FOR THE PIPING OF A 80 VOLT BATTERY
Gepr.			
Norm			
Zust Änderung Datum Name			Zeichnungs-Nr. / DWG NO.
bfs ing. klaus oschmann mitterweg 9 - 11 85230 bergkirchen			nicht tolerierte Freimaße nach DIN 16901 UNLESS OTHERWISE SPECIFIED TOLERANCING PER DIN 16901